



Refrigerator Temperature Log Template

conducted for

Downtown Grocery Chain

Conducted on

22 Feb 2019 08:23 AM

Prepared by

Johnny Cruz

Location

622-626 Kohler St
Los Angeles, CA 90021
United States
(34.03870380278119, -118.2411241958007)

Completed on

22 Feb 2019 08:16 AM

Score



0/0.0 - 0.00%



Failed Responses

This section lists responses that were set as "failed responses" in the template used for this audit

Question	Response	Details
Temperature:	42 °F	

Audit

Question	Response	Details	
Temperature Log			
+ Add Temperature Reading			
Temperature Reading 1			
Item:	1 dozen yogurt		
Temperature:	42 °F		
If 41-44°F, immediately relocate to another cooler that is 40°F then repair current cooler. If 45°F or above, discard items and repair current cooler.			
Action taken:	Placed in the new fridge. Asked Minni to come over and fix the old fridge.		
Photo (optional):			
			
Appendix 1			
Name and signature of inspector	Johnny Cruz	22 Feb 2019 08:15 AM	
Temperature Reading 2			
Item:	2 dozen soda		
Temperature:	37 °F		

Question	Response	Details	
<p>Photo (optional):</p>  <p>Appendix 2</p>			
<p>Name and signature of inspector</p>	<p>JC</p>	<p>22 Feb 2019 08:15 AM</p>	

Media



Appendix 1



Appendix 2