



# Daily Pool Log Template

Daily Pool Log Template

Complete

Inspection score	Failed items	Created actions
<b>35.00%</b>	<b>1</b>	<b>0</b>
Pool Name Outdoor Olympic Pool		
Month	June	
Year 2019		
Pool Operator/Pool Manager Johan Johnston		
Location 5178 Arvinels Ave, San Diego, CA 92117, USA		
Conducted on 📅 25th Jun, 2019 ⌚ 1:21 PM +08		

## Failed items

1 Failed

---

### Daily Pool Log / Pool Log / Pool Log 1

• pH	6.8
------	-----

# Daily Pool Log

1 Failed 35.00%

## Pool Log

### Pool Log 1

1 Failed

• Date and Time 📅 25th Jun, 2019 🕒 1:37 PM +08	
Temperature (F) 76	
• Water Clarity	Clear
• Disinfectant	Stabilized Chlorine (Tablets or granules containing Dichlor or Trichlor)
Free Chlorine (ppm)	4 From 0.5 to 11
• Combined Chlorine (ppm)	0.2 From 0 to 1
• Total Chlorine (Free Chlorine + Combined Chlorine) 4.2	
• pH	6.8
Raise the pH, add soda ash (sodium carbonate)	
• Flow GPM 73	
• Bather Load 8	

### Sign Off

Comments Added soda ash and pH is now 7.6
--

Name and Signature



Johan Johnston

25th Jun, 2019 1:49 PM +08