



Your Quick Fire Extinguisher Inspection Checklist

Tower 1 / Level 6 / SafetyCulture Staff / 18 Jun 2021

Complete

Score	92.86%	Failed items	0	Actions	0
Conducted on	18th Jun, 2021 11:19 AM PST				
Building	Tower 1				
Select Floor	Level 6				
Full Name of Inspector	SafetyCulture Staff				
Location	2 Lacey St, Surry Hills NSW 2010, Australia (-33.8858808, 151.2116917)				

Inspection

92.86%

Quick Fire Extinguisher Inspection

92.86%



Click to add fire extinguisher to be inspected

Fire Extinguisher

92.86%

Fire Extinguisher 1

92.86%

Is there a fire extinguisher on this floor/level?

Yes

Where is this fire extinguisher located on the floor you are on?

Meeting Room

Accessibility

100%

Take a photo of the fire extinguisher and its storage location from within a few feet.



Photo 1

Is the fire extinguisher easily visible?

Yes

Is there adequate signage above the fire extinguisher?

Yes

Is the fire extinguisher elevated from the ground?

Yes

Is the fire extinguisher's immediate surrounding free from obstruction?

Yes

Is the fire extinguisher easily removable from its bracket/container? (For fire extinguishers inside glass cabinets, it is alright to not move them anymore)

Yes

Physical

100%



Come closer to the fire extinguisher for visual inspection.

Enter Serial Number (e.g. can be found on the inspection tag or somewhere on the cylinder)

Not Available

Is the cylinder tank and all external metal parts free of corrosion, dents or other signs of damage?

Yes

Is the sticker/label on the cylinder in readable?

Yes



Is the hose free of cracks or other signs of damage?

Yes



Have a look at the inside of the nozzle. Does it show any leak?

No



Is the locking pin present and intact?

Yes

Is the seal present and not broken? (The seal's material can be plastic or metal)

Yes

Pressure Gauge

100%

Locate the pressure gauge at the top of the cylinder. Here is an example of a pressure gauge.



Is the pressure gauge pointed within the optimal green range [refer image above]?

Yes

Inspection Tag

0%

Was a completed inspection for the previous month reflected on the inspection tag?

No

Completion

Your summary of observations

Check for inspection tags, remember when the last inspection was conducted, and to do consistent fire extinguisher inspections



SafetyCulture Staff

18th Jun, 2021 11:29 AM PST

Appendix

Appendix



Photo 1