



Refrigerator Temperature Log Template

Complete

Score	0%	Flagged items	0	Actions	1
Branch	Downtown Grocery Chain				
Conducted on	13.01.2023 18:56 PST				
Prepared by	Johnny Cruz				
Location	622 Kohler St, Los Angeles, CA 90021, USA (34.0387598, -118.2411482)				

Actions

1 action

Audit / Temperature Log / Temperature Reading / Temperature Reading 1

Action taken:

Placed in the new fridge. Asked Minni to come over and fix the old fridge.

Complete | Priority High | Due 21.01.2023 18:58 PST | Created by SafetyCulture Staff

Fridge broken. Needs fixing.

Hello Minni! Old fridge needs fixing. Would you come over please? Thanks!

Audit

1 action

Temperature Log

1 action

+ Add Temperature Reading

Temperature Reading

1 action

Temperature Reading 1

1 action

Item:

1 dozen yogurt

Temperature:

42°F
Should be less than or equal to 40°F

If 41-44°F, immediately relocate to another cooler that is 40°F then repair current cooler.
If 45°F or above, discard items and repair current cooler.

Action taken:

Placed in the new fridge. Asked Minni to come over and fix the old fridge.

Complete | Priority High | Due 21.01.2023 18:58 PST | Created by SafetyCulture Staff

Fridge broken. Needs fixing.

Hello Minni! Old fridge needs fixing. Would you come over please? Thanks!

Photo (optional):



Photo 1

Name and signature of inspector



Johnny Cruz
13.01.2023 19:01 PST

Temperature Reading 2

Item:

2 dozen soda

Temperature:

37°F
Should be less than or equal to 40°F

Photo (optional):



Photo 2

Name and signature of inspector

JC
13.01.2023 19:01 PST

Appendix



Photo 1



Photo 2