



Safety Work Instruction Template

Confined space work associated with plumbing of sewerage / E-123 / RA1246 / John Marco / 15 Jun 2023

Complete

| | | | | | |
|-------|-----------|---------------|----------|---------|----------|
| Score | 0% | Flagged items | 0 | Actions | 0 |
|-------|-----------|---------------|----------|---------|----------|

Title / Description of Activity

Confined space work associated with plumbing of sewerage

Created by

John Marco

Document No.

E-123

Risk Assessment No.

RA1246

Initial Issue Date

15.06.2023

Current Version

Version 1

Next Review Date

01.12.2023

Instruction

Safe Work Instruction

Scope

Confined space work associated with the plumbing of sewerage

Authorizations

Environmental and natural resources policies

Prestart Requirements

- Ensure permits are posted
 - Wear appropriate Personal Protective Equipment (PPE)
 - Ensure that the guardrails are properly installed
 - Maintain a 3-point grip when using the scaffold
 - Conduct atmosphere tests
-

Hazards

- Suffocation
 - Hazardous or decaying substance that may produce a hazardous atmosphere
-

Safety Controls

- Install barricade/s at the entrance
 - Install a proper ventilation system
 - Delegate a walkaround watch who can call rescue for emergencies
-

Instructions

* Disclaimer: This is an example of how you can use SafetyCulture to include work instructions.

1. Use the drone to check/inspect the sewer to point out the clog
 2. Install barricade and put signage at the entrance
 3. Wear appropriate PPE
 4. Ensure that the guardrails are installed properly
 5. Use equipment for clog removal
-

Closing Procedures

1. Seal off the sewage properly
 2. Remove the barricade and signage
-

Emergency Procedures

- Delegate a walkaround watch who can call rescue for emergencies
 - Call the emergency rescue team
 - Perform emergency rescue operation
 - Bring the patient to the nearest hospital if necessary
-

Completion

Created by (Name and Signature)



John Marco
15.06.2023 09:25 PST
